

Spill Summary Report for NRC Report #1297893

Report Date: 9/14/2022

Report Time: 4:09 PM EDT

Region II Hotline Log Entry Information

Data ID: 2770735

Date Of Report: 2/12/2021

NRC #: 1297893

State #:

ERNS #:

Material Type: Oil

Receiver: Gaughan

Material / Amount:

DIELECTRIC FLUID (390 GALLON(S));

Location:

Street: 237 FRONT ST

City: MANHATTAN

County: NEW YORK (MANHATTAN)

State: NY

Latitude: 40.70781765361937

Longitude: -74.0013953689382

Source of Pollution:

CONSOLIDATED EDISON COMPANY OF NEW YORK

Water Body:

State Or EPA Responded:

RP/PRP Response

Initial EPA Action:

ConEd investigating potential leak. See Action Report.

Status:

2 - Closed

URL:

Associated Action Reports

DataID: 1259217

Date: 2/17/2021	Time: 15:06:52	
Duty Officer/Responder Name: Daniel Gaughan	NRC Report #: 1297893	Hotline Log DataID: 2770735
Action Information		
Description: ConEd feeder cable leak in cable 38M12. As of 2-17-2021 at 1500 hours, ConEd still trying to locate leak. Cable runs between Manhattan and Brooklyn. Clean up will occur once leak is located.		
Follup-Up: Contacted PRP		
Person Contacted		
Name: Tim Reagan Organization: ConEd Phone #: 212-580-8383		

NRC Spill Report

NATIONAL RESPONSE CENTER 1-800-424-8802

GOVERNMENT USE ONLYGOVERNMENT USE ONLY***

Information released to a third party shall comply with any applicable federal and/or state Freedom of Information and Privacy Laws

Incident Report # 1297893

INCIDENT DESCRIPTION

*Report taken by NRC on 12-FEB-21 at 19:39 ET.

Incident Type: FIXED

Incident Cause: UNKNOWN

Affected Area:

Incident occurred on 12-FEB-21 at 19:28 local incident time.

Affected Medium: OTHER / UNKNOWN SOURCE

REPORTING PARTY

Name: PAUL WALSH

Organization: CONSOLIDATED EDISON COMPANY OF NEW YORK

Address: 3101 20TH AVENUE

ASTORIA, NY 11105

Email Address:

PRIMARY Phone: (212)5808383

Type of Organization: PUBLIC UTILITY

SUSPECTED RESPONSIBLE PARTY

Name: PAUL WALSH

Organization: CONSOLIDATED EDISON COMPANY OF NEW YORK

Address: 3101 20TH AVENUE

ASTORIA, NY 11105

PRIMARY Phone: (212)5808383

Type of Organization: PUBLIC UTILITY

INCIDENT LOCATION

237 FRONT ST County: NEW YORK (MANHATTAN)

City: MANHATTAN State: NY

RELEASED MATERIAL(S)

CHRIS Code: OTH Official Material Name: OTHER OIL
Also Known As: DIELECTRIC FLUID
Qty Released: 390 GALLON(S)

DESCRIPTION OF INCIDENT

CALLER STATED 390 GALLONS OF DIELECTRIC FLUID DISCHARGED FROM A FEED CABLE
TO AN UNKNOWN SOURCE. THE CAUSE OF THE DISCHARGE IS ALSO UNKNOWN AT THIS TIME.

INCIDENT DETAILS

Package: N/A
Building ID:
Type of Fixed Object: OTHER
Power Generating Facility: UNKNOWN
Generating Capacity:
Type of Fuel:
NPDES:
NPDES Compliance: UNKNOWN

IMPACT

Fire Involved: NO Fire Extinguished: UNKNOWN
INJURIES: NO Sent to Hospital: Empl/Crew: Passenger:
FATALITIES: NO Empl/Crew: Passenger: Occupant:
EVACUATIONS: NO Who Evacuated: Radius/Area:

Damages: NO

<u>Closure Type</u>	<u>Description of Closure</u>	<u>Hours Closed</u>	<u>Direction of Closure</u>
Air:	NO		
Road:	NO		Major Artery: NO
Waterway:	NO		

Track: NO

Passengers Transferred: NO
Environmental Impact: UNKNOWN
Media Interest: NONE

REMEDIAL ACTIONS

CREWS ARE PULLING MANHOLE COVERS, AND VEHICLE ARE TRYING TO TRACE THE GAS
SOURCE AT THIS TIME, INVESTIGATION IS UNDERWAY
Release Secured: UNKNOWN
Release Rate:
Estimated Release Duration:

WEATHER

ADDITIONAL AGENCIES NOTIFIED

Federal:
State/Local:
State/Local On Scene:
State Agency Number:

NOTIFICATIONS BY NRC

CENTERS FOR DISEASE CONTROL (GRASP)
12-FEB-21 19:48 (770)4887100
CHEM SAFETY AND HAZARD INVEST BOARD (MAIN OFFICE)
12-FEB-21 19:48
DEPT OF HEALTH AND HUMAN SERVICES (SECRETARY OPERATION CENTER (SOC))
12-FEB-21 19:48
DHS INFRSTR SECURITY COMPLIANCE DIV (REGION 2)
12-FEB-21 19:48 (202)4655909
DOT CRISIS MANAGEMENT CENTER (MAIN OFFICE)
12-FEB-21 19:48 (202)3661863
U.S. EPA II (MAIN OFFICE)
12-FEB-21 19:57 (732)3214370 MR GAUGHAN
FEMA REGION 2 (MAIN OFFICE)
12-FEB-21 19:48 (877)5689043
NATIONAL INFRASTRUCTURE COORD CTR (MAIN OFFICE)
12-FEB-21 19:48 (202)2829201
NJ OFC HMLND SECURITY & PREPAREDNESS (COMMAND CENTER)
12-FEB-21 19:48 (609)9636817
NJ STATE POLICE (MARINE SERVICES BUREAU)
12-FEB-21 19:48 (609)9636900

NOAA RPTS FOR NY (MAIN OFFICE)
12-FEB-21 19:48 (206)5264911
NEW YORK DHS EMERGENCY SERVICES (OEM - R1/NYC)
12-FEB-21 19:48 (626)6316834
NY STATE DEC SPILL HOTLINE (MAIN OFFICE)
12-FEB-21 19:48 (518)4577362
PIPELINE & HAZMAT SAFETY ADMIN (HAZARDOUS MATERIAL ACCIDENT INVESTIGATION)
12-FEB-21 19:48 (202)3664031
SECTOR NEW YORK (COMMAND CENTER)
12-FEB-21 19:54 (718)3544356 PO COHEN
TSA OFFICE OF SECURITY OPERATIONS (ALBANY COMPLIANCE OFFICE)
12-FEB-21 19:48 (518)4528938
USCG DISTRICT 1 (COMMAND CENTER)
12-FEB-21 19:48 (617)2238555

ADDITIONAL INFORMATION

NY DEP AND NY DEC WILL BE NOTIFIED NEXT.

*** END INCIDENT REPORT # 1297893 ***
Report any problems by calling 1-800-424-8802
PLEASE VISIT OUR WEB SITE AT <http://nrc.uscg.mil>